



Read me first!

Attention FCWnx and Secure Perfect users:

In order for the firmware version icon on the controller monitor screen to properly display Green, indicating the latest version of DirecDoor firmware, you must rename the file as follows; otherwise the icon will continue to display Yellow, indicating that the firmware needs to be updated.

To rename the DirecDoor firmware file:

- [Secure Perfect 6.1.1](#)
 1. Browse to the folder: `\Program Files\GE Interlogix\Secure Perfect\Firmware`
 2. Right-click the file, `DD7111.efl` and select Rename.
 3. Type: `DD7011.efl`
 4. Log off and then log back on to the system in order for the host to detect the update.

- [FCWnx](#)
 1. Browse to the folder: `\Program Files\GE\FCWnx\Firmware`
 2. Right-click the file, `DD7111.efl` and select Rename.
 3. Type: `DD7011.efl`
 4. Log off and then log back on to the system in order for the host to detect the update.